

Butte-Silver Bow Fire Department

Firework Stand Site Location and Inspection

Location:

Owner/Operator:

Address:

Phone:

Set up Distance

“No Smoking” signs

Sales People

Extinguisher

Electrical

Locale

Approved

Violation/note

The above location and stand have been (Fireworks may be sold only in roadside stands or buildings used for no other purpose)

Approved _____ Disapproved _____ on

Site only _____ Site and Stand _____

By: Fire Marshal _____

Zones C-2, M-1, M-2

Set up Distance 150' from any structure
(Minimums) 30' from any public roadway
15' from any fire hydrant
150' from flammable liquid dispensing devices.
25' clear of weeds and grass

Discharging of Fireworks no fireworks shall be discharged within 100' of the stand.

Open Flames no open flame devices
Within 25' of the stand

No Smoking Signs Sign shall have letters at least 4" in height

Sales People Shall be age 18 or older.

Extinguisher One (1) 2A (two-1/2 gallon), pressurized water extinguisher (or equivalent) inside each stand less than thirty (30) feet; two (2) 2A (two-1/2 gallon), pressurized water extinguishers (or equivalent) inside each stand greater than thirty (30) feet in length

Electrical No electrical cords shall be strung across public ways. All electrical wiring shall meet the standards of the National Electrical Code.

Parking No parking of any vehicle that transports any flammable or combustible within 100' of the stand

Sale dates Not before June 24 or after July 5

Exits No members of the general public shall be allowed inside the stand.

Inspection all stands shall be subject to inspection by the Fire Chief. Firework stands shall be securely locked when not open for business, or all fireworks removed to a safe location approved by the local fire official. Portable generators (and fuel) used for supplying power to consumer fireworks sales facilities shall be located not less than 20 feet from the stand and in an area free from grass, trash and other combustible/flammable materials.