

BSB Municipal Codes and BSB Construction Requirements. (in-street excavation)

BSB Municipal Codes:

12.04.070 - Permit Fees

\$25.00 for up to 40 Lineal Feet (\$0.50 per foot after)

12.04.080 - Bonding

\$1000 for each opening up to 40 feet (\$7.00 for each additional foot) or \$6000

12.04.100 - Construction requirements

Use MPWSS Grade B or approved

Tack coat shall be applied to square cut edges just prior to patching

Asphalt shall be a minimum of 4" for Residential and Commercial

Asphalt shall be a minimum of 6" on State or Urban Routes

5 sack concrete shall be used from November 1st to March 31st. Concrete shall be replaced with hot mix as soon as Hot Plants are operating.

Warranty-the Holder of the permit shall warrant the work in Public ROW to be free from settlement and surface condition for 2 years following the completion and acceptance.

12.04.250 - When the cut line is 3 feet or less from the edge of existing pavement, remove and replace the entire pavement section.

12.04.270 - Trench Backfilling

All backfill shall be non-plastic, granular material and placed in 6" lifts compacted to 95% compaction (+/-3% moisture)

Base Course: Per BSB Construction requirement need a minimum of 6" crushed base course per MPWSS and compacted to a minimum of 95% density (+/-3% moisture) per ASHTO T-99.

NOTE: 2 year warranty starts at time of BSB signing off on final Hot Patch.

12.04.290 - Minimum of \$300.00 fine for each offence including patching within the 15 days.

Road
In-Street Excavation Requirements

Revised: 2/27/2012



Standard Drawing

R-REQ1

NOT TO SCALE